

**AN ORDINANCE PROVIDING FOR THE AMENDMENT OF SECTION 90.110 , FIRE PREVENTION CODE, OF THE CODE OF ORDINANCES OF THE CITY OF OLIVETTE, MISSOURI AND THE AMENDMENT OF SECTION 90.115 OF THE CODE OF ORDINANCES OF THE CITY OF OLIVETTE, MISSOURI ON THE SAME SUBJECT.**

**WHEREAS**, three copies of the code hereinafter referenced have been on file with the City Clerk of the City of Olivette for at least ninety days prior to the enactment of this Ordinance; and

**WHEREAS**, all of the procedures required by law for the adoption of a technical code by reference under the Laws of the State of Missouri have been satisfied;

**NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF OLIVETTE, MISSOURI AS FOLLOWS:**

SECTION 1. REPEAL OF PRIOR ORDINANCE; ADOPTION OF CODE AND AMENDMENTS

Section 90.110 of the Municipal Code of Ordinances of the City of Olivette, Missouri is hereby repealed and a new Section 90.110 of the Municipal Code of Ordinances of the City is hereby enacted in lieu thereof to read as follows:

**FIRE PREVENTION AND PROTECTION**

90.110 ADOPTION OF FIRE PREVENTION CODE.

That a certain document, three (3) copies of which are on file in the office of the City Clerk of the City of Olivette, Missouri, being marked and designated as the ICC International Fire Code, 2006 Edition, as published by the International Code Council, Inc., together with the standards which are referenced in Chapter 45 and including Appendix Chapters B, C, D, E, F and G be and is hereby adopted as the Fire Prevention Code of the City of Olivette , Missouri, for the control of buildings and structures as herein provided; and each and all of the regulations, provisions, conditions, and terms of the ICC International Fire Code/2006, First Edition, are hereby referred to, adopted and made a part hereof, as if more fully set out in this Ordinance, with the additions, insertions, deletions and changes prescribed in this Ordinance.

## SECTION 2. AMENDMENTS TO INTERNATIONAL FIRE CODE

Section 90.115 of the Municipal Code of Ordinances of the City of Olivette, Missouri is hereby repealed and a new Section 90.115 of the Municipal Code of Ordinances of the City is hereby enacted in lieu thereof to read as follows:

The Fire Prevention Code adopted in Section 90.110 is hereby amended as fully set forth in the chapters and sections as specified herein below. The chapter and section numbering format of the ICC International Fire Code/2006, First Edition is used herein to enhance the understanding of the code by maintaining a consistent format throughout the code; thus, the chapter and section numbers appearing herein as changes to the ICC International Fire Code/2006, First Edition shall be consistent with said code. All amendments contained herein are part of Chapter 90 of the Municipal Code of Ordinances of the City of Olivette, Missouri and shall be considered as though the numeral --- and a hyphen precede them.

### AMENDMENTS TO THE ICC INTERNATIONAL FIRE CODE/2006, FIRST EDITION.

Section 101.1 is amended by substituting "The City of Olivette, Missouri" for [NAME OF JURISDICTION] on line two thereof.

Section 103.1 delete existing text. Insert:

**103.1 General.** The Bureau of Fire Prevention is established within the jurisdiction under the direction of the code official. The function of the bureau shall be the implementation, administration and enforcement of the provisions of this code.

Section 103.2 delete existing text. Insert:

**103.2 Enforcement Official.** It shall be the duty and the responsibility of the chief executive officer, designated as the fire chief, to enforce the provisions of this code. The fire chief shall be the Code Official.

Section 103.2.1 add a new section. Insert:

**103.2.1 Bureau Organization.** The bureau of fire prevention shall operate under the direct supervision of the fire marshal. The fire marshal shall be a uniformed member and chief officer of the fire department and operate under the direct supervision of the fire chief. The fire marshal shall be appointed on the basis of his/her administrative abilities and qualifications to understand, interpret and enforce the technical provisions of this code. All uniformed members of the fire department shall be considered members of the bureau of fire prevention. The fire marshal may assign or appoint technical assistants, inspectors or other employees that may be necessary for the effective and efficient operation of the bureau of fire prevention. All appointments to the bureau shall be made in conformance with the provisions of the municipal code.

Section 103.3 delete existing text. Insert:

**103.3 Bureau members code enforcement duties and authority.** The fire marshal, and all properly assigned or appointed members of the bureau of fire prevention shall have the duty to assist the fire chief in the administration and enforcement of the provisions of this code. As agents of the fire chief, all properly assigned or appointed members of the bureau of fire prevention shall have the authority to exercise all of the powers of the code official as detailed within this code.

Section 104.11.4 add a new section as follows. Insert:

**104.11.4 Compliance with orders.** A person shall not willfully fail or refuse to comply with any lawful order or direction of the fire official or to interfere with the compliance attempts of another individual.

Section 104.11.5 add a new section as follows. Insert:

**104.11.5 Vehicles crossing hoses.** A vehicle shall not be driven or propelled over any unprotected fire hose of the fire department when laid down on any street, alleyway, private drive or any other vehicular roadway without the consent of the fire official in command of said operation.

Section 104.11.6 add a new section as follows. Insert:

**104.11.6 Vehicles following emergency apparatus.** It shall be unlawful for the operator of any vehicle, other than one on official emergency business, to follow closer than 300 feet from any fire apparatus or other emergency vehicle traveling in response to a fire alarm or other emergency or to drive any vehicle within the block or immediate area where a fire apparatus or other emergency vehicle has stopped in answer to a fire alarm or other emergency.

Section 104.11.7 add a new section as follows. Insert:

**104.11.7 Unlawful boarding or tampering with emergency equipment.** A person shall not, without proper authorization from the fire official in charge of said fire department emergency equipment, cling to, attach oneself to, climb upon or into, board or swing upon any fire department emergency vehicle, whether the same is in motion or at rest; or sound the siren, horn bell or other sound-producing device thereon; or manipulate, remove or tamper with, or attempt to manipulate, remove or tamper with any levers, valves, switches, starting devices, brakes, pumps or any equipment or protective clothing on, or a part of, any fire department emergency vehicle.

Section 104.11.8 add a new section as follows. Insert:

**104.11.8 Damage or injury to fire department equipment or personnel.** It shall be unlawful for any person to damage or deface, or attempt to damage or deface, any fire department emergency vehicle at any time or to injure, or attempt to injure, fire department personnel while performing departmental duties.

Section 105.3.3 delete existing text. Insert:

**105.3.3 Occupancy prohibited before approval.** The building or structure shall not be occupied prior to the fire code official approving the issuance of a permit that indicates that applicable provisions of this code have been met.

Section 105.6.48 add a new section. Insert:

**105.6.48 Helicopter landing/lift-off, hoisting and lowering operations.** An operational permit is required for helicopter landing/lift-off, hoisting and lowering operations in accordance with the following. Proof of financial responsibility must be submitted to the code official before a permit is issued.

The helicopter service or the contractor in charge of a helicopter landing/lift-off, hoisting or lowering operations shall demonstrate financial responsibility of liability for damages arising from the landing/lift-off, hoisting or lowering operation by providing the code official with proof of insurance or other appropriate financial responsibility. The amount of financial liability shall be adequate for the payment of all damages which may be caused either to a person or persons, or to property by reasons of the permitted operation, and arising from any actions, or in-actions, of the permit holder, or the permit holder's, employees, agents, contractors or subcontractors.

Permit applications must include a description of the landing/lift-off operation or work to be performed and the safety precautions to be used. Forty-eight hours notice shall be provided before the landing/lift-off, hoisting or lowering operation is to begin.

**Exceptions:**

1. Emergency or precautionary landings.
2. Law enforcement or medical evacuation operations.
3. Other operations approved by the code official.

Section 105.6.48.1 add a new section. Insert:

**105.6.48.1 Safety precautions.** During all helicopter landing/lift-off, lifting or lowering operations, the following applicable safety precautions shall be followed:

The fire and police departments shall approve landing sites, if landings are necessary. All materials or equipment to be lifted shall be brought as close as possible to the building or structure site by road vehicles.

The helicopter shall not carry equipment or materials lifted to or lowered from a building or structure over pedestrians, spectators, other buildings or vehicles.

When the operation involves setting or removing equipment or materials from or on an occupied building, the top 2 floors of the building shall not be occupied by anyone, other than individuals directly involved with the operation while the hoisting or lifting operation is in progress.

All flammable or combustible liquids brought to the site for refueling helicopters shall be stored, used and dispensed in accordance with Chapters 11 and 34 of this code.

A fire department safety officer, or fire department safety team, must be present on the site during all helicopter landing/lift-off, lifting or lowering operations. The safety officer, or safety team, shall terminate the landing/lift-off or lift if weather conditions or other variables make the operation unsafe. The safety officer, or safety team, shall be provided radio communications with the helicopter pilot in the event safety conditions mandate evasive action.

**Exceptions:**

4. Emergency or precautionary landings.
5. Law enforcement or medical evacuation operations.
6. Other operations approved by the code official.

Section 108.1 delete existing text. Insert:

**108.1 Board of Appeals.** Any person shall have the right to appeal a decision of the code official to the Board of Building Appeals as provided under Section 112 of the Building Code of the City of Olivette or section R112 of the City of Olivette Residential code as applicable. Procedures and requirements of appeals brought under this section shall be set forth in section 112 or R112 of the respective code.

Section 109.3 delete existing text. Insert:

**109.3 Penalties.** Any person who violates a provision of this code or fails to comply with any of the requirements thereof or who erects, alters, or repairs a building or structure in violation of the approved construction documents or directive of the building official, or of a permit or certificate issued under the provisions of this code shall be subject to penalties as prescribed by law.

Section 109.3.2 add a new section as follows. Insert:

**109.3.2 False alarms.** In the event of false alarms, after the second false alarm in any twelve-month period, the alarm user, in lieu of court appearance, may pay to the director of finance a penalty of fifty dollars (\$50.00), and further, after the third false alarm in any twelve-month period, the alarm user, in lieu of court appearance, may pay to the director of finance a penalty of one hundred dollars (\$100.00). For the fifth and subsequent false alarms in any twelve-month period the penalty shall be an amount that is double the amount of the prior penalty (e.g. fifth false alarm, \$200.00, sixth false alarm, \$400.00, etc.) plus court costs of \$25.00 for each offense thereafter.

Section 111.4 delete existing text. Insert:

**111.4 Failure to comply.** Any person who shall continue any work after having been served with a stop work order, except such work that a person is directed to perform to remove a violation or unsafe condition, shall be guilty of an ordinance violation and punished as provided in Section 109.3 of this code.

Section 112 add a new section as follows. Insert:

## **SECTION 112 UNSAFE CONDITIONS**

**112.1 General.** Whenever the code official shall find in any structure or upon any premises dangerous or hazardous conditions or materials as follows, the code official shall order such hazardous conditions or materials to be removed or remedied in accordance with the provisions of this code:

1. Hazardous conditions liable to cause or contribute to the spread of fire in or on said premises or structure or endanger the occupants thereof;
2. Conditions that interfere with the efficiency or operation of any fire protection equipment or system;
3. Obstructions to or on fire escapes, stairs, passageways, doors or windows, that are liable to interfere with the egress of occupants or the operation of the fire department in case of fire;
4. Accumulations of dust or waste material in air-conditioning or ventilating systems or grease in kitchen or other exhaust ducts;
5. Accumulations of grease on kitchen cooking equipment, or oil, grease or dirt upon, under or around any mechanical equipment;
6. Accumulations of rubbish, waste, paper, boxes, shavings or excessive storage of any combustible material;
7. Hazardous conditions arising from defective or improperly utilized or installed electrical wiring, equipment or appliances;
8. Hazardous conditions arising from defective or improperly installed equipment for handling or using combustible, explosive or otherwise hazardous materials;
9. Dangerous or unlawful amounts of combustible, explosive or otherwise hazardous materials; and
10. All equipment, materials, processes or operations that are in violation of the provisions or intent of this code.

Section 303.10.1 add a new section as follows. Insert:

**303.10.1 Safety precautions.** All operations shall comply with the following safety precautions:

1. Fired asphalt (tar) kettles shall not be left unattended.
2. Torches or other flame-producing devices shall be fueled with LP gases only.
3. LP gas containers or cylinders shall be stored in accordance with Chapter 38 of this code and with NFPA 58 listed in Chapter 45 of this code.
4. Torches, flame-producing devices, containers, cylinders, regulators, hoses and other equipment must be designed and approved for the specific purpose intended.
5. LP gas containers or cylinders shall not be transported to the roof in elevators or exit stairways that are occupied by non-construction personnel.
6. Flames from the torch shall not impinge on combustible "Cant Strips" or other combustible structural elements.
7. A firewatch shall be established and conducted in accordance with Section 2604.2 of this code. The firewatch person shall be provided with water hoses connected to an adequate water supply on the premises. The firewatch person shall remain on the premises and in position to observe residual fire effects at least one (1) hour after each use of the torch or flame-producing device.
8. Before a torching operation begins, the site shall be inspected and approved by the fire department. Where climatic, operational or construction conditions warrant specific inspections or observations, a fire department employee shall act as an additional firewatch.

Section 401.3.1 delete in its entirety. Insert:

**401.3.1 Making false report.** It shall be unlawful for any person to willfully or maliciously give, turn in, signal, transmit or cause to be made, a false alarm or report that a fire or medical emergency has occurred, or is in progress, by any action or means whatsoever, and said false alarm or report causes the unnecessary movement or use of fire department apparatus or personnel, or causes the evacuation of building occupants or the disruption of the building occupant's normal activities.

Section 508.1.1 add a new section as follows. Insert:

**508.1.1 Public water supply.** The fire prevention code official shall recommend to the chief administrative official of the municipality the location or relocation of new or existing fire hydrants and the placement or replacement of inadequate water mains located upon public property and deemed necessary to provide an adequate fire flow and distribution pattern. A fire hydrant shall not be placed into or removed from service until approved by the fire prevention code official.

Section 508.5.7 add a new section. Insert:

**508.5.7 Color coding of public fire hydrants.** All public and private fire hydrant barrels are to be painted yellow. All fire hydrant bonnets are to be painted as follows:

<b>COLOR</b>	<b>WATER MAIN SIZE</b>
Green	Twelve (12) inch and larger
Orange	Eight (8) and ten (10) inch
Red	Six (6) inch and smaller

Section 607.2.1 add a new section as follows. Insert:

**607.2.1 Information signs.** An approved graphic display of evacuation routes and written information concerning basic evacuation procedures, including the location of the exit stairs, shall be posted in an approved location in all common hallways, in or near elevator lobbies, on all floor levels of all new and existing high rise buildings.

Section 607.4 add a new section as follows. Insert:

**607.4 Elevator emergency operations testing.** All elevators that are equipped with emergency elevator operations in accordance with Rule 211.3 of ASME A17.1 listed in Chapter 45, shall be tested at least once each year in all phases of emergency functions. An approved elevator service company shall conduct tests.

Section 607.5 add a new section as follows. Insert:

**607.5 Prohibited lockout systems, key-ways and devices.** Elevator service shall be provided for fire department emergency access to all floors in all high rise buildings. The use of security lockout systems, key operated floor selection buttons or other key-ways or other devices which are not automatically rendered inoperative by the fire sensing devices or the key-operated fire service master switch is prohibited. Walls, security bars, equipment, or storage may not obstruct access to any building level from any elevator.

Section 806.1.1 delete in its entirety, including exception. Insert:

**806.1.1 Restricted occupancies.** Natural cut trees shall be prohibited in Group A, B, E, I-1, I-2, I-3, I-4, M, R-1, R-2 and R-4 occupancies.

Exception:

Trees located in areas protected by an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2 shall not be prohibited in Groups A, B, E, M, R-1 and R-2.

Section 901.6.2 delete in its entirety. Insert:

**901.6.2 Records.** Records of all system inspections, tests and maintenance required by the referenced standards shall be maintained on the premises for a minimum of 3 years. If the required testing frequency is greater than 3 years, records must be kept for the number of years of the testing frequency plus 3 years. All records shall be made available to the code official upon request.

Section 901.6.2.1 delete in its entirety. Insert:

**901.6.2.1 Records information.** Accurate logs shall be maintained indicating the number, location and type of device tested. Any defect, modification, maintenance, inspection, testing or repair shall be logged. Initial records shall include the name of the installation contractor, type of components installed, manufacturer of the components, location and number of components installed per floor. Records shall also include the manufacturers' operation and maintenance instruction manuals. Such records shall be maintained on the premises.

Section 901.6.3 add a new section as follows. Insert:

**901.6.3 High-rise standpipe tests.** In addition to the standards listed in Table 901.6.1, standpipe flow tests approved by the code official shall be conducted in accordance with NFPA 25 listed in Chapter 45 on standpipe systems in all high-rise buildings every 2 years. The flow shall not be less than the flow demands required at the time of installation, or not less than 200 GPM at the topmost hose outlet while maintaining a residual pressure of 50 psi, whichever is the higher demand. At the time of the test, all control valves, including those inside hose cabinets, shall also be operated and tested to insure proper operation of the valves. The results of the tests must be submitted to the code official and also must be entered into the log book.

Section 903.3.8 add a new section as follows. Insert:

**903.3.8 No parking areas at fire department connections:** When fire department connections are located in an area where vehicles may be parked or standing, said parking or standing shall be restricted for ten (10) feet in each direction from the fire department connection.

Section 903.3.1.1.2 add a new section as follows. Insert:

**903.3.1.1.2 Sprinklers required.** Clean agent, halogenated or carbon dioxide extinguishing systems shall not be considered as an alternative to an automatic sprinkler system in computer rooms, vaults or other rooms where an automatic sprinkler system is required.

Section 903.4.2.1 add a new section as follows. Insert

**Section 903.4.2.1 Alarm.** The alarm for the sprinkler system shall be a approved UL horn and strobe for exterior use. This will be located above the fire department connection. Location will be approved by the fire marshal.

Section 907.3 delete in its entirety. Insert:

**907.3 Where required—retroactive in existing buildings and structures.** An approved manual, automatic or manual and automatic fire alarm system shall be installed in existing buildings and structures in accordance with Sections 907.3.1 through 907.3.1.9. Where automatic sprinkler protection is provided in accordance with Section 903.3.1.1 or 903.3.1.2 and connected to the building fire alarm system, automatic heat detection required by this section shall not be required.

An approved automatic fire detection system shall be installed in accordance with the provisions of this code and NFPA 72. Devices, combinations of devices, appliances and equipment shall be approved. The automatic fire detectors shall be smoke detectors, except an approved alternative type of detector shall be installed in spaces such as boiler rooms where, during normal operation, products of combustion are present in sufficient quantity to actuate a smoke detector.

Section 907.3.1.9 add a new section as follows. Insert:

**907.3.1.9 High-rise buildings.** An approved automatic fire alarm system shall be installed in existing high rise buildings. The system shall be monitored in accordance with Section 907.15. The enunciator panel shall be installed in a location approved by the code official and shall give visual indication of the location of all alarm zones that may be in alarm. Systems that are upgraded shall be designed and installed in accordance with the requirements of Section 907.2.12. of this code.

Section 907.13.1 add a new section as follows. Insert:

**907.13.1 Detector indicators .** Smoke detectors or duct detectors located above a ceiling or behind a wall must be provided with a remote indicating device in an approved location at the ceiling or wall to indicate the location of the device.

**Exception:** Where approved by the code official.

Section 907.15 delete in its entirety. Insert:

**907.15 Monitoring.** All fire alarm and detection systems shall be monitored by an approved central station as defined in NFPA 72. A UL Certificate or FM Placard, in accordance with the 2002 Edition of NFPA 72 Chapter 8, shall be issued by the UL

Listed or FM Approved prime contractor for all newly installed required fire alarm systems. This regulation shall apply to all newly installed required fire alarm systems with an installation permit issued on or after October 1, 2007. An existing required fire alarm system wherein the control panel and alarm components are to be replaced, shall be considered newly installed for the purposes of this section. The code official shall maintain a listing of local UL Listed or FM Approved prime contractors. Central station service in full compliance with the 2002 Edition of NFPA 72 Chapter 8 shall be maintained at the protected property, so long as the requirement for the fire alarm system exists.

Exceptions:

1. Proprietary and Remote Station systems where approved by the Code Official.
2. Fire alarm and detection systems in one- and two-family dwellings.

Section 907.15.1 add a new section as follows. Insert:

**907.15.1 Fire alarm systems monitoring.** Central-station monitoring centers must be listed by Underwriters Laboratories. Monitoring information, including company name, address and phone number, method of transmission and UL listing information shall be provided. Where deemed necessary by the code official, the UL listing information shall be provided along with a copy of the UL Fire Alarm Certificate for the appropriate category ( Central Station, Remote Station, or Proprietary).

Section 909.20.6 add a new section as follows. Insert:

**909.20.6 Stairway pressurization systems.** Stairway pressurization systems that supply air to interior exit stairways to provide a positive pressure in stairways shall be tested annually. Stairways shall be pressurized to a minimum of 0.15 inches of water column and a maximum of 0.35 inches of water column in the stairway relative to the pressure in the building with all stairway doors closed under the maximum anticipated stack pressure.

Section 912.1.1 add a new section as follows. Insert

**Section 912.1.1 Fire department connection.** The Olivette Fire Department requires installation of “*The Olivette Connection*” which consists of a single 5” Storz and a single 2 ½” Siamese FDC on all sprinklers and standpipes. The 5” Storz connection shall measure 30-40 inches from the finished grade and project *downward* at a 45 degree angle. An UL approved exterior horn and strobe will also be installed. The installer shall consult the Fire Department for the location of the Fire Department Connection and any questions concerning its installation and approval.

Section 1027.22 add a new section as follows. Insert:

**1027.22 Exterior floor identification dots.** All new and existing hi-rise buildings shall be marked on their exterior with floor level identification dots. These dots shall be not less than 8 inches in diameter and be of an approved illumination reflective material. Dots shall identify every fifth floor level of the building, in relationship to the floor level indicators on the elevator cars. Dots shall be visible on all faces or sides of the building. Specific dot locations must be approved by the fire department.

Section 1027.23 add a new section as follows: Insert:

**1027.23 Firefighter assist plans.** An approved pictographic display (sign, drawing or wall marking) shall be posted within all enclosed stairways at each floor landing in all new and existing high-rise buildings. Individual displays, or signs shall show the floor level number where the graphic is displayed, the configuration of exit access corridors including all door openings, exit stairways, elevators, exterior building walls, fire alarm pull stations, fire hoses and sprinkler valves. The sign shall be located 5 feet (1524 mm) above the floor landing in a position that is readily visible when the doors are in the open or closed positions.

Section 1027.24 add a new section as follows: Insert:

**1027.24 Pressurized stairways.** All enclosed exit stairways in all new and existing high rise buildings shall comply with Section 1020.1.7. Pressurization equipment for pressurized stairways shall be activated by smoke detectors installed on the building side of all stairway doors in an approved location. ON-AUTO-OFF control switches shall be provided in the Fire Command Center as required by Section 909.16xz.

Section 1028.8 add a new section as follows. Insert:

**1028.8 Maintenance.** The means of egress from each part of the structure, including exits, stairways, egress doors and any panic hardware installed thereon, aisles, corridors, passageways and similar elements of the means of egress, shall at all times be maintained in a safe condition and available for immediate utilization and free of all obstructions.

Section 2204.3.8 add a new section. Insert:

**2204.3.8 Fire suppression system.** The dispensing area (pump islands, canopy and adjacent ground area) shall be provided with an approved fire suppression system.

Section 2703.5.2 add a new section as follows: Insert:

**2703.5.2 Hazard signals required.** Any occupancy required by this code and/or state law to provide material safety data sheets, shall provide visible markings on the outside of buildings, rooms and containers where hazardous substances are present. These markings shall be in a location approved by the code official. These markings shall

conform to the NFPA 704 marking system or with other federal laws or regulations, or in the case of containers, may as an option comply with Safety and Health Administration Hazard Communication Rule, 29 CFR 1910.1200(f). To avoid duplication of markings, marking requirements of the United States Department of Transportation shall satisfy the requirements in regard to motor vehicles, rolling stock and aircraft.

Section 2703.5.3 add a new section as follows:

**2703.5.3 Main entrance.** Where required by Section 2703.5, all buildings shall have a placard located on the main entry door a minimum of 18" from the bottom edge of the door. This placard shall have a minimum dimension of 5". This placard is not required to be lettered or numbered.

Section 2703.5.4 add a new section as follows:

**2703.5.4 Other doors.** All other doors shall have a placard with a minimum dimension of 10" located in an approved location that identifies the worst hazard category of the product(s) in that area. This placard shall be provided with numerals in accordance with Section 2703.5.5.

Section 2703.5.5 add a new section as follows:

**2703.5.5 Signal size.** The exterior markings of buildings or site entrances where materials are stored shall have a minimum signal size of 4". All numbers/letters shall be reflective.

Section 3301.1.3 modify as follows: **Delete** Exception #4 in its entirety.

Section 3301.2.4 delete in its entirety.

Section 3404.3.2.4 add a new section as follows:

**3404.3.2.4 Storage cabinets.** Unless otherwise mandated by this code, all flammable and combustibles must be stored in an approved flammable liquids storage cabinet. Cabinet doors must be kept closed.

Section 3404.2.13.1.4 modify as follows: **Delete** Exception for item #3 in its entirety.

Section D103.6 add a new section as follows. Insert:

**D103.6.3 Fire lanes.** Fire lanes so legally designated by the chief of the fire department shall be posted with appropriate signs or markings as specified by the chief of the fire department and approved by the board of aldermen so that the public will be aware of the existence of such fire lanes. If said fire lanes are marked by painting them, then they shall be painted red in color. In cases of fire lanes established on private property, the owner thereof, shall provide such signs or markings at his expense and in cases of fire lanes established on public property, the director of public works shall provide such signs or markings at the expense of the City of Olivette.

SECTION 2. SAVINGS CLAUSE.

That nothing in this Ordinance or in the Fire Prevention Code hereby adopted shall be construed to affect any suit or proceeding pending in any Court, or any rights acquired or liability incurred, or any cause or causes of action acquired or existing under any act or Ordinance hereby repealed, as cited in Section 2; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this Ordinance.

SECTION 3. VALIDITY.

If any Section, subsection, provision, sentence, clause or phrase of this Ordinance or of the ICC International Fire Code/2006, First Edition, is for any reason, held to be unconstitutional or invalid, such decision shall not affect the validity of the remaining portions of this Ordinance or of said Code, and the City of Olivette of St. Louis County, Missouri, hereby declares that it would have passed the same, even though such portions so held to unconstitutional had not been included therein.

City of Olivette Ordinance deletions

150.010  
150.020  
150.030  
150.040  
150.050  
150.060  
150.070

170.191      170.193

90.010  
90.020  
90.030  
90.040  
90.050.  
90.060

90.070.  
90.080  
90.090  
90.110  
90.115  
90.120  
90.130  
90.140  
90.210  
90.220  
90.230  
90.240  
90.250  
90.310  
90.320  
90.330  
90.340  
90.350

**PASSED THIS 22<sup>ND</sup> DAY OF JANUARY, 2008.**

*Ruth Springer*  
\_\_\_\_\_  
**MAYOR RUTH SPRINGER**

**ATTEST:**

*Myra G. Bennett*  
\_\_\_\_\_  
**MYRA G. BENNETT, CMC/MRCC  
CITY CLERK**